

MEMORANDUM

To: All Interested Vendors

From: Procurement Department,
Columbus Metropolitan Library

Date: March 11, 2025

Subject: Addendum No. 3 – CML 25-005 Carnegie Gutter Sealing Project
Summary of Virtual Meeting
Questions and Answers

Part I. Virtual Meeting

Columbus Metropolitan Library conducted a virtual meeting on Monday, March 10, 2025 at 2:00 pm. The following CML representatives were present:

Andrew Kistler, Director Property Management
Wanda Dixon, Procurement Analyst

A representative from Freedom Roofing, Windows and Siding was also in attendance.

Part II. Questions and Answers

Q1. Does the EPDM get installed underneath the flashing of the existing copper roof or is it getting stripped in on top?

A1. See attached pictures which show how the EPDM and metal sections are configured.

Q2. What is getting reinstalled on the wall section where the EPDM goes up the wall where the two buildings meet?


A2. See attached picture

All Proposals must be received no later than 12:00 Noon on March 17 2025, ET.

PROPOSERS ARE REQUIRED TO ACKNOWLEDGE THE RECEIPT OF THIS MEMORANDUM (ADDENDUM NO. 2) ON THE ACKNOWLEDGEMENT OF THE ADDENDA FORM IN THE RFP DOCUMENTS




EPDM membrane tucked under metal strip.



EPDM membrane tucked under metal strip.

EPDM wrapped under coping cap.

EPDM sealed at edge of gutter pan.



The panels behind the EPDM sounds like lightweight board.

The surface under the EPDM sounds like metal cooper gutter pan.